

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160500, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, Unit:300, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, July 18, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING SPACES: **3F029 THRU 3F034;**

Comments: