
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20152896, Public Works Infrastructure Permit - Residential
Trails of Parks Ridge 2nd

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Sanitary Sewer - Mandrel	Tom Chandler	Passed	Monday, July 18, 2016

Informational

1 Tom Chandler 07/15/2016 Pulled mandrel on all sections of pipe and passed. Used 7.37 mandrel.

PW-Sanitary Sewer - Air Test	Tom Chandler	Passed	Monday, July 18, 2016
------------------------------	--------------	--------	-----------------------

Informational

1 Tom Chandler 07/15/2016 Sanitary sewer Air testing is complete and all sections passed. Tested for 7min34sec.

PW-Sanitary Sewer - Vacuum	Tom Chandler	Passed	Monday, July 18, 2016
----------------------------	--------------	--------	-----------------------

Informational

1 Tom Chandler 07/15/2016 Vacuum tested all Manholes for 2min30sec. and all passed.

Comments:
