

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160556, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, July 18, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: SPACES A118; A121;	

Gas Piping Inspection - Commercial	John Borns	Partial	Monday, July 18, 2016
Partial Correction 1 Misc 1		GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MINUTES AT SPACES: A118; A121;	

Comments: