

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160556, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

In-wall Inspection	John Borns	Partial	Monday, July 18, 2016
---------------------------	------------	---------	-----------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING SPACES: SPACES A118 &
A121;

Gas Piping Inspection - Commercial	John Borns	Partial	Monday, July 18, 2016
---	------------	---------	-----------------------

Partial Correction
1 Misc 1

GAS PIPING PRESSURE TEST AT A118; A121 OK EXCEPT HIGH
GAUGE IN A118 TO BE RE-TESTED BY P.C. TO ENSURE NO LEAKS.

Comments: