

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20160496, Building Permit - Residential  
Address: 3110 SE 3RD TER, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Partial	Wednesday, July 20, 2016

### Corrective Action Required

1 Misc 1

-VENT WATER HEATER

(MAKE SURE UFFER IS ACCESSABLE AT FINAL)

OKAY TO SHEETROCK, WILL CHECK REMAINING ITEMS AT FINAL.  
NOTE, FOAM INSULATATION COVERED UFFER GROUND.

### Comments: