

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Wednesday, July 20, 2016

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	*STORM SEWER AT THE FOLLOWING LOCATIONS* 12" STORM LINE AT 15 LINE SLOPING EAST BETWEEN O AND R TO 10.5 LINE. TRANSITION TO 8" LINE TO AA LINE.
---	----------------------------------	--

Partial Correction

2	THE FOLLOWING AREAS ARE APPROVED	AREA C: SANITARY WASTE AND VENT 2 INCH TO 4 INCH AT W LINE TO 10 LINE WITH BATH GROUP; 6" PVC ON (K.8) FROM (11.6) TO (14) + FIVE BRANCHES;
---	----------------------------------	---

Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, July 20, 2016
---	------------	---------	--------------------------

Partial Correction

1	Misc 1	NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP: THREE 4" PVC CONDUITS UNDER GRADE BEAM AT DD/13.2 TO 80' NORTH; THREE 4" + TWO 1-1/2" PVC CONDUITS EXTENDED N TO SERVER RM; SIX 3" + ONE 1-1/4" FROM SERVER RM SW TO ~T/11, THEN TWO 3" S TO Z/10.25;
---	--------	---

Comments: