

**AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

# Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

|                                                   |            |          |                         |
|---------------------------------------------------|------------|----------|-------------------------|
| Inspection:                                       | Inspector: | Outcome: | Date:                   |
| <b>Underslab Plumbing Inspection - Commercial</b> | John Borns | Partial  | Thursday, July 21, 2016 |

## Partial Correction

|   |                                  |                                                                                                                                                    |
|---|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | THE FOLLOWING AREAS ARE APPROVED | *STORM SEWER AT THE FOLLOWING LOCATIONS*<br>12" STORM LINE AT 15 LINE SLOPING EAST BETWEEN O AND R TO 10.5 LINE. TRANSITION TO 8" LINE TO AA LINE. |
|---|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|

## Partial Correction

2 THE FOLLOWING AREAS ARE APPROVED AREA C: SANITARY WASTE AND VENT  
2 INCH TO 4 INCH AT W LINE TO 10 LINE WITH BATH GROUP; 6" PVC ON (K.8) FROM (11.6) TO (14) + FIVE BRANCHES;

## Partial Correction

3 Misc 1 OK TO COVER WHEN READY UNDER-SLAB DRAIN LINES IN  
PROGRESS AT: AREA "A"; AREA "C" SE;

|                                                     |            |         |                         |
|-----------------------------------------------------|------------|---------|-------------------------|
| <b>Underslab Electrical Inspection - Commercial</b> | John Borns | Partial | Thursday, July 21, 2016 |
|-----------------------------------------------------|------------|---------|-------------------------|

## Partial Correction

|   |        |                                                                                                                                                                                                                                                                                                                                                                                                                                             |
|---|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc 1 | NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP: THREE 4" PVC CONDUITS UNDER GRADE BEAM AT DD/13.2 TO 80' NORTH; THREE 4" + TWO 1-1/2" PVC CONDUITS EXTENDED N TO SERVER RM; SIX 3" + ONE 1-1/4" FROM SERVER RM SW TO ~T/11, THEN TWO 3" S TO Z/10.25; <b>THREE 1-1/2" PVC FROM SERVER RM TO WALL PENETRATIONS AT K/13.5; TWO 2" PVC FROM WALL PENETRATIONS AT K/13.5 TO SW -- SWEEPING TO WEST N OF SERVER RM;</b> |
|---|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**