



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20160500	Date:	July 25, 2016
Project Title:	SAINT LUKES EAST - BREAST CENTER SUITE 300	Applicant:	
Location:	110 NE SAINT LUKES BLVD, Unit:300, LEES SUMMIT, MO 64086	CENTURY FIRE SPRINKLERS, INC 1901 BEDFORD NORTH KANSAS CITY, MO 64116	
Type of Work:		Primary:	(816) 556-0808
Occupancy Group:	B		
Description:	NEW TENANT FOR MEDICAL EXAMS AND DIAGNOSTIC IMAGING - SUITE 300		
Construction Type:	Type IA		
Map Page:	175X		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. FIELD ACCEPTANCE TESTING MAY BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TOV SCHEDULE TESTING CONTACT THE FIRE DEPARTMENT AT 816-969-1300

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed. THE EXISTING FIRE SPRINKLER RISERS SHALL BE CURRENT WITH THE REQUIRED ANNUAL SERVICE/MAINTENANCE WITH CURRENT TAGS ON THE RISERS. (VERIFIED AT INSPECTION)

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**