
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161367, Public Works Infrastructure Permit - Commercial
John Knox Village - Meadows
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Fire Line - Hydrostatic Test Informational	Steve Robbins	Passed	Tuesday, July 26, 2016
1	On 7/25/16 the hydrostatic pressure test was completed. we also flushed the line and and chlorinated the water line. Steve Robbins 07/26/2016 3:49 PM		

Comments:
