

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRCOM20161763

Address: 310 SW BLUE PKWY, LEES SUMMIT, MO 64063

Inspected On: Thursday, July 28, 2016

Inspected By: John Borns

Expiration Date: 8/4/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Thursday, July 28,

Codes Commercial

Corrective Action Required:

1 Misc 1 ELECT RECEPT AT N WALL OF OFFICE NOT SECURED TO BOX. USE

BOX EXTENDER DUE TO EXCESSIVE SET-BACK OF BOX.

2016

Corrective Action Required:

2 Misc 1 AFFIX "NO SMOKING" STICKER TO PUBLIC ENTRANCE DOOR.

Corrective Action Required:

3 Misc 1 RESOLVE FIRE DEPARTMENT ISSUES.