

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161367, Public Works Infrastructure Permit - Commercial
John Knox Village - Meadows
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Coliform Test 1 Informational	Steve Robbins	Passed	Thursday, July 28, 2016
1	Today I took the first samples for the water line down to the lab. The line has been flushed , chlorinated and dechlorinated. Steve Robbins 07/27/2016 4:39 PM		
Informational			
2	Sample 1 of the coliform test passed today. I took the second sample down to the lab. Steve Robbins 07/28/2016 4:15 PM		

Comments: