

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160737, Building Permit - Commercial  
Address: 403 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Friday, July 29, 2016

Corrective Action Required  
1 Misc 1

ABOVE-CEILING INSPECTION REQUESTED AT RESTROOMS ONLY:  
VENT FANS NOT DUCTED TO EXTERIOR. DO NOT COVER. REQUEST  
RE-INSPECTION WHEN READY.

**Comments:**