

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161245, Building Permit - Commercial
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Partial	Friday, August 05, 2016

Corrective Action Required

1	Misc 1	AREA OVER FRONT ENTRY-PARTAIL NEED TO INSTALL 3 SUPPLY VENTS. -INSIDE ENTRY,INCOMPLETE CEILING AND ELECTRICAL. RECALL FOR MONDAY
---	--------	--

Underslab Plumbing Inspection - Commercial	Mark Harding	Passed	Friday, August 05, 2016
---	--------------	--------	-------------------------

Comments: