

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Monday, August 08, 2016

Partial Correction

1 Misc 1

**OK TO COVER WHEN READY: TWELVE 3" PVC SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION TO BUILDING ENTRY;**

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Monday, August 08, 2016
---	------------	---------	-------------------------

Partial Correction

1 THE FOLLOWING AREAS ARE APPROVED

STORM SEWER AT THE FOLLOWING LOCATIONS:  
12" STORM LINE AT 15 LINE SLOPING EAST BETWEEN O AND R TO 10.5 LINE; TRANSITION TO 8" LINE TO AA LINE; 8" PVC LINE FROM E.2/11.5 TO E.2/9.3; 10" PVC FROM E.2/9.3 TO K.2/9.3; 10" & 8" PVC FROM W.8/4 TO W.8/3.4 TO X.1/3.4 TO RISER @ X.1/2; 8" PVC FROM 4.8/B.8 4.8/H.2; 6" PVC FROM H.2/5.2 TO 4.7/H.2; 10" PVC FROM H.2/4.7 TO {TWO 4" C.O.s} H.2/2.6 TO 2.6/L TO UNDER G.B. TO 5' O/S B/L @ L/2; **6" PVC FROM G/6 & J/6 CONVERGING @ H.2/5.6 AND CONNECTING TO PREVIOUS RUN AT H.2/5.2;**

Partial Correction

2 THE FOLLOWING AREAS ARE APPROVED

SANITARY WASTE AND VENT  
2 INCH TO 4 INCH AT W LINE TO 10 LINE WITH BATH GROUP; 6" PVC ON (K.8) FROM (11.6) TO (14) + FIVE BRANCHES; 4" PVC FROM T.5/9.2 TO T.5/5.6 TO N.2/5.6 TO N.2/4.2; 6" PVC ON (K.8) FROM (11.6) TO (10.3) + 4" BRANCH SOUTH AT (10.3);

Partial Correction  
3 Misc 1

OK TO COVER WHEN READY UNDER-SLAB DRAIN LINES AT: AREA  
"A" COMPLETE; AREA "C" COMPLETE N OF (K);

**Comments:**