
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20160642, Public Works Infrastructure Permit - Commercial
Missouri Innovation Campus
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Fire Line Construction Inspection	Steve Robbins	Passed	Wednesday, August 10, 2016

Informational

- 1 Inspected the fire line coming out of the building. All thrust blocks and restraining joints were in place. Glen Martin will now be taking this project over for the remainder of it. Steve Robbins 08/10/2016 1:34 PM

Comments:
