

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160560, Building Permit - Commercial
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Thursday, August 11, 2016

Corrective Action Required

1 Misc 1

GLAZING, WHEN INSTALLED, MUST BE SAFETY GLASS

Partial Correction

2 Misc 1

**OCCUPANCY STATUS: OK FOR USE & OCCUPANCY. REQUEST
RE-INSPECTION SAME DAY GLAZING IS INSTALLED.**

Comments: