

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160937, Building Permit - Residential
Address: 400 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Partial	Friday, August 12, 2016

Corrective Action Required

1	Misc 1	-REAR DECK ATTACHED TO CANTILEVER, THIS MUST BE HEADERED OR INSTALL POSTS. WILL CHECK AT FINAL.
		OKAY TO ROCK

Comments: