

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161193, Building Permit - Commercial
Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, August 12, 2016

Corrective Action Required

1 Misc 1

OK TO COVER ACT CEILING SYSTEM EXCEPT AT:

- EXHAUST HOSES AT BOTH RR VENT FANS NOT CONNECTED
- R.A. GRILLE LYING ABOVE CEILING IN KITCHEN

OK TO COVER ELSEWHERE

Comments: