

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160556, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Friday, August 12, 2016

Corrective Action Required

1 Misc 1

GLAZING, WHEN INSTALLED, MUST BE SAFETY GLAZING.

Corrective Action Required

2 Misc 1

**USE/OCCUPANCY STATUS: OK FOR USE IF APPROVED BY FIRE
DEPT. PENDING INSPECTION OF GLAZING WHEN INSTALLED.**

Alarm Test	Michael Weissenbach	Failed	Friday, August 12, 2016
-------------------	------------------------	--------	-------------------------

Comments: