

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161763, Building Permit - Commercial  
Address: 310 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	<b>Failed</b>	Wednesday, August 17, 2016

Corrective Action Required

2 Misc 1

AFFIX "NO SMOKING" STICKER TO PUBLIC ENTRANCE DOOR.

Corrective Action Required

1 Misc 1

ELECT RECEPT AT N WALL OF OFFICE NOT SECURED TO BOX. USE  
BOX EXTENDER DUE TO EXCESSIVE SET-BACK OF BOX.

**Comments:**