

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20160414 Date: August 22, 2016

Project Title: HT SOLUTIONS Applicant:

Location: 1440 SE BROADWAY DR, LEES

1440 SE BROADWAY DR, LEES
SUMMIT, MO 64081

SUMMIT, MO 64081

ELECTRONIC CONTRACTING COMPANY
6020 Parretta Drive
Kansas City, Mo 64120

Type of Work:

Occupancy Group: F-2

Description: NEW BUILDING FOR THE Primary: (816)561-6800

MANUFACTURING OF METAL

PARTS

FOUNDATION/UNDERSLAB PERMIT: PRCOM20160805

Construction Type: Type IIB (Unprotected)

Map Page: 195R

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Joe Dir Released for Construction

- 1. PROVIDE MANUFACTERS SPECS ON ALL DEVICES TO BE INSTALLED. EMAIL TO joe.dir@cityofls.net
- 2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

 ACCEPTANCE TESTING OF THE SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE TESTING CONTACT THE FIRE DEPARTMENT AT 816-969-1300.

3. PLANS SHOW PROJECT ADDRESS AS 1220 SE BROADWAY. CORRECT PROJECT ADDRESS IS 1440 SE BROADWAY (INFORMATION PURPOSES)

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.