



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161721	Date:	August 22, 2016
Project Title:	THAI SPICE EXPANSION	Applicant:	BAMFORD FIRE SPRINKLER CO INC
Location:	1192 NE DOUGLAS ST, LEES SUMMIT, MO 64086		5134 MERRIAM DR
Type of Work:	SYSTEM MODIFICATION		SHAWNEE MISSION, KS 66203
			(913) 432-6688

Occupancy Group: A-2
Description: RESTAURANT TO EXPAND INTO
ADJACENT SPACE TO PROVIDE ADDITIONAL
SEATING AND BAR AREA
Construction Type: Type VB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

A visual inspection will be completed at the Occupancy Inspection.

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Action required: The existing system shall have documentation of a current annual inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.