

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161583, Building Permit - Commercial
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	John Borns	Passed	Tuesday, August 23, 2016
Final Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, August 23, 2016

Comments: METER DEPTH BELOW LID IS SET TO 18". CLOSE PERMIT.