PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160557, Building Permit - Commercial Address: 2600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Mark Harding Partial Tuesday, August 23, 2016

Inspection - Commercial

Corrective Action Required

1 Misc 1 MDP- service and grounds in place.

need to check electrical to scoreboard.

and transformer set up.

Comments: