

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161018, Building Permit - Commercial
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, August 24, 2016

Corrective Action Required

1 Misc 1

GRADE BEAMS AND PIERS OK BELOW:
-EXTERIOR GB AND PILASTERS OK, EXCEPT AT VEHICLE
DRIVE-THROUGH AT SOUTH END

**GROUNDING CONNECTION TO FOOTING REBAR NOT DONE

Comments: