

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, August 25, 2016

Partial Correction

1 Misc 1

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP **THROUGHOUT EXCEPT TWO 3" YET TO BE COMPLETED AT AREA "B" NEAR (Q)**

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Thursday, August 25, 2016
---	------------	---------	---------------------------

Partial Correction

1 THE FOLLOWING AREAS ARE APPROVED

STORM SEWER AT THE FOLLOWING LOCATIONS:  
12" STORM LINE AT 15 LINE SLOPING EAST BETWEEN O AND R TO 10.5 LINE; TRANSITION TO 8" LINE TO AA LINE; 8" PVC LINE FROM E.2/11.5 TO E.2/9.3; 10" PVC FROM E.2/9.3 TO K.2/9.3; 10" & 8" PVC FROM W.8/4 TO W.8/3.4 TO X.1/3.4 TO RISER @ X.1/2; 8" PVC FROM 4.8/B.8 4.8/H.2; 6" PVC FROM H.2/5.2 TO 4.7/H.2; 10" PVC FROM H.2/4.7 TO {TWO 4" C.O.s} H.2/2.6 TO 2.6/L TO UNDER G.B. TO 5' O/S B/L @ L/2; 6" PVC FROM G/6 & J/6 CONVERGING @ H.2/5.6 AND CONNECTING TO PREVIOUS RUN AT H.2/5.2;

Partial Correction

2 THE FOLLOWING AREAS ARE APPROVED

OK TO COVER WHEN READY PVC DWV PIPING: AREA "A" COMPLETE; 2 INCH TO 4 INCH AT W LINE TO 10 LINE WITH BATH GROUP; 6" PVC ON (K.8) FROM (11.6) TO (14) + FIVE BRANCHES; 4" PVC FROM T.5/9.2 TO T.5/5.6 TO N.2/5.6 TO N.2/4.2; 6" PVC ON (K.8) FROM (11.6) TO (10.3) + 4" BRANCH SOUTH AT (10.3); 2"

Partial Correction

3 Misc 1

THEN 4" PVC FROM F/9.5 TO K.8/9.3 TO K.8/10.3; 2" THEN 3"  
THEN 4" PVC FROM Y.5/3.7 TO T.5/3.9 TO T.5/6.5; 4" FROM  
F.2/9.6 TO F.2/2.8 + 2" BRANCH FROM F/9.1 TO F.2/9.1 + 2"  
BRANCH FROM B/6.8 TO F.2/6.8 + 4" W.C. BRANCH @ F.2/6.8;

UNDER-DRAIN PIPING OK TO COVER AT: AREA "A", "C"; **"B" & "D"**  
**IN PROGRESS;**

**Comments:**