



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20162031 Date: August 26, 2016
Project Title: ART & FRAME WAREHOUSE Applicant:
Location: 107 SE M 291 HWY, LEES SUMMIT, AMERICAN FIRE SPRINKLER CORPORATION
MO 64063 PO BOX 958
Type of Work: MISSION, KS 66201
Occupancy Group: M Primary: (913) 722-6900
Description: CHANGE OF TENANT FOR
NEW SALES AND FRAMING
OF ART

*plans are in plan review file

Construction Type: Type VB (Unprotected)
Map Page: 195H

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH ALL OF THE REQUIRED
SERVICE/MAINTENANCE FOR THE SYSTEM. A CURRENT SERVICE TAG SHALL BE POSTED ON THE
SPRINKLER SYSTEM RISER. (VERIFIED AT INSPECTION)

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.