

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20150529, Building Permit - Residential
Address: 3328 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Friday, August 26, 2016

Corrective Action Required

1	Misc 1	-BOLT DECK TO HOUSE -GARAGE DOOR REQUIRED TO BE SELF CLOSING -SUPPORT DBL RIM BEAM FOR DECK WHERE MEETS THE HOUSE. NO SUPPORT. - INSTALL SECURITY BLOCKING AT BSMT DOOR - INSTALL ALL SECURITY DOOR SCREWS AND HARDWARE AT ALL DOORS AND STRIKE PLATES.
---	--------	---

Comments: