

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152357, Building Permit - Commercial
Address: 471 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Passed	Tuesday, August 30, 2016

Gas Piping Inspection - Commercial	John Borns	Passed	Tuesday, August 30, 2016
---	------------	--------	--------------------------

Comments:

- 1) INFRASOURCE, A CERTIFIED GAS LINE INSTALLER, HAS BEEN BEEN LISTED ON THE PERMIT IN LIEU OF A LICENSED PLUMBING CONTRACTOR FOR INSTALLATION OF THE GAS FEEDER TO THE GENERATOR.
- 2) INFRASOURCE PROVIDED INSPECTION HOLES FOR JB TO OBSERVE MATERIAL AND DEPTH OF GAS LINE FROM THRIFT SHOP NORTH WALL TO GENERATOR LOCATION; DEPTH WAS FOUND TO BE >12" CODE MINIMUM.
- 3) INFRASOURCE PRESSURED-UP GAS LINE TO >10 PSI LS CODE MINIMUM. PRESSURE HELD STEADY FOR >10 MINUTES LS CODE MINIMUM.
- 4) EXPOSED BLACK IRON GAS PIPE HAS BEEN PAINTED TO PREVENT CORROSION PER IFGC 404.8.

NO REMAINING ISSUES. CLOSE PERMIT.