

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152912, Building Permit - Commercial
Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Commercial	Khanh Nguyen	Failed	Monday, September 12, 2016

Corrective Action Required

1	Misc 1	-SEWER HOLDING TANK TOO CLOSE TO THE FOOTING, UNDERMINING THE FOOTING. HAVE ENGINEER ADDRESS THIS
---	--------	--

Water Service Inspection - Commercial	Khanh Nguyen	Partial	Monday, September 12, 2016
--	--------------	---------	----------------------------

Comments: