

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20161289, Building Permit - Residential
Address: 421 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Monday, September 12, 2016

Corrective Action Required

1	Misc 1	-FIREBLCOK FIRST FLOOR MECH CHASE -SOLID BLOCK OVER GARAGE BEAM
---	--------	--

Electrical Service Inspection - Residential	Mike Copeland	Passed	Monday, September 12, 2016
--	---------------	--------	----------------------------

Gas Piping Inspection - Residential	Mike Copeland	Passed	Monday, September 12, 2016
--	---------------	--------	----------------------------

Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, September 12, 2016
---	---------------	--------	----------------------------

Comments: