



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20151897 Date: September 16, 2016
Project Title: HOLIDAY INN EXPRESS Applicant:
Location: 1201 NW INNOVATION PKWY, KELLER FIRE & SAFETY
LEES SUMMIT, MO 64086 1138 KANSAS AVE
KANSAS CITY, KS 66105
Type of Work:
Occupancy Group: R-1
Description: NEW 4 STORY 90 ROOM Primary: (913) 371-8494
HOTEL
Construction Type: Type VA (1 hour)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. ACCEPTANCE TESTING FOR THE FIRE ALARM SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.