

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161721, Building Permit - Commercial  
Address: 1192 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection -</b> <b>Codes Commercial</b>	John Borns	Not Ready	Friday, September 16, 2016

Corrective Action Required

1 Misc 1

RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required

2 Misc 1

ELECTRICAL RECEPTACLE BOXES AT THREE LOCATIONS NEED BOX EXTENDERS.  
NEC 370-20; IRC E3806.5-6 SET-BACK OF ELECTRICAL RECEPTACLE / SWITCH BOXES: MUST BE **FLUSH WITH COMBUSTIBLE WALL SURFACE; 1/4" MAXIMUM SET-BACK @ NON-COMBUSTIBLE SURFACES.**

Corrective Action Required

3 Misc 1

NEC 110 - 26 (a) (b); IRC 3305.1: **DEDICATED WORKING/CLEAR SPACE AT ELECTRICAL PANEL** MUST BE MINIMUM OF 30" BY 36" DEEP

**Comments:**