

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20160414
Project Title: HT SOLUTIONS

Location:

1440 SE BROADWAY DR, LEES

SUMMIT, MO 64081

Type of Work:

Occupancy Group: F-2

Description: NEW BUILDING FOR THE

MANUFACTURING OF METAL

PARTS

FOUNDATION/UNDERSLAB

PERMIT: PRCOM20160805

Construction Type: Type IIB (Unprotected)

Map Page: 195R

Date: September 20, 2016

Applicant:

ADVANTAGE FIRE PROTECTION SYSTEMS INC

404 B NW 11TH ST

BLUE SPRINGS, MO 64015

Primary: (816) 224-3400

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Joe Dir Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

FIELD AND ACCEPTANCE TESTING OF THE SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.