

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152455, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Wednesday, September 21, 2016
Partial Correction 1            Misc 1		OK TO COVER WHEN READY CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS: <b>FROM A/7 TO E/7 TO E/6.8;</b>	

**Comments:**