

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162424, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Thursday, September 22, 2016
Final Electrical Inspection - Commercial	John Borns	Passed	Thursday, September 22, 2016

Comments: RELEASE 200A TEMPORARY ELECTRICAL SERVICE AT LOCATION OF PERMANENT TRANSFORMER TO BE INSTALLED.