

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162211, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Thursday, September 22, 2016

**Comments: NO ISSUES FOUND ON NEW PVC DWV PIPING. 20" SECTION OF COMPRESSED EXISTING
WATER LINE REPLACED. OK TO COVER WHEN READY.**