

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162317, Building Permit - Residential
Address: 1317 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Partial	Thursday, September 22, 2016

Corrective Action Required

1 Misc 1

-TWO GARAGE PADS ARE AT EDGE OF OVERDIG AND ARE UNDERMINED. FILL THE OVERDIG WITH CLEAN GRAVEL AND HAVE THIS INSPECTED

Comments: