

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161204, Building Permit - Commercial
Address: 2724 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, September 22, 2016

Corrective Action Required

1	Misc 1	-FIRE DEPT. APPROVAL REQUIRED. SPRINKLER HEAD UNDER MEZZANINE NOT INSTALLED -PROVIDE CITY-APPROVED PLAN ON SITE -COLUMN SUPPORT PADS NOT INSTALLED. HAVE ENGINEER ADDRESS
---	--------	---

Occupancy Inspection - Fire	Michael Weissenbach	Failed	Thursday, September 22, 2016
--	------------------------	--------	------------------------------

Comments: