

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, September 23, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS: FROM A/7 TO E/7 TO E/6.8; E/6.8 TO E/2 TO D.3/1.2; **D.3/1.2 to D/1 TO 1/B.2;**

Comments: