

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Friday, September 23, 2016

Partial Correction
1 Misc 1

**INSPECTIONS WITH FRAMING CONTRACTOR OF EXTERIOR
SHEAR WALLS. OK TO COVER ALL ELEVATIONS -- FULL HEIGHT.**

Corrective Action Required
2 Misc 1

PRELIMINARY OBSERVATIONS WITH FRAMING CONTRACTOR OF
INTERIOR SHEAR WALLS AT FIRST FLOOR. SHEAR WALLS ARE
INCOMPLETE AND ARE NOT READY FOR FULL INSPECTION AT
FIRST FLOOR.

Comments: