

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161080, Building Permit - Commercial
Address: 521 SE 2ND ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Monday, September 26, 2016

Comments: NO CODE VIOLATION FOUND ON UNDER-SLAB ELECTRICAL WIRING TO FOUR DENTAL CHAIR LOCATIONS. BOX LOCATIONS AND ELEVATION TO BE VERIFIED BY CONTRACTORS AND BUSINESS OWNER. OK TO COVER WHEN READY.