

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20161419, Building Permit - Residential
Address: 401 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mike Copeland	Failed	Monday, September 26, 2016

Corrective Action Required

1	Misc 1	NO PRESSURE ON GAS LINE FOR TEST.
---	--------	-----------------------------------

All Rough Inspection - Residential	Mike Copeland	Failed	Monday, September 26, 2016
---	---------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-INSTALL FIREPLACE -HOLES CUT FOR PLUMING AT REAR OF HOUSE FOR SECOND FLOOR JOISTS AT BEARING POINT. MANUFACTURER PROHIBITS HOLS DRILLED AT BEARING LOCATIONS. SEE LAYOUT. PROVIDE ENGINEER FIX OR REPLACE AND RE-PLUMB. -PROVIDE CLEARANCE FOR 12 GUAGE ROMEX TO B-VENT OVER KITCHEN CEILING. -LATERAL JOIST SUPPORT REMOVED FOR M.E.P. SYSTEMS THROUGHOUT, INSTALL 2x4 SUPPORT TOP AND BOTTOM CORDS. OKAY INSULATE
---	--------	--

Electrical Service Inspection - Residential	Mike Copeland	Passed	Monday, September 26, 2016
--	---------------	--------	----------------------------

Gas Piping Inspection -	Mike Copeland	Passed	Monday, September 26, 2016
--------------------------------	---------------	--------	----------------------------

Residential

Comments: