

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152438, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|  |            |          |                                  |
|--|------------|----------|----------------------------------|
| Inspection:  | Inspector: | Outcome: | Date:                            |
| <b>Rough Framing<br/>Inspection -<br/>Commercial</b> | John Borns | Failed   | Wednesday, September 28,<br>2016 |

Corrective Action Required

1      Misc 1

VERTICAL LIGHT-GAUGE STEEL FRAMING AT ROOF HEIGHT  
TRANSITIONS:

- 1) CHECK ALL DEFLECTION CLIPS AND ENSURE SCREWS ARE AT  
MID-HEIGHT OF SLOTS AND ARE SET SOLID**
- 2) COMPLETE SCREWING OF FLANGES AT BOTTOM TRACK AT  
ONE E-W LINE**

Comments: