

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161245, Building Permit - Commercial  
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Friday, September 30, 2016

Corrective Action Required

1	Misc 1	CLINIC APPROVED
		MARKET GRILL- ONLY REMAINING AREA IS EXISTING KITCHEN AND STORE TIE IN CEILING AREAS.

**Comments:**