

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162211, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Monday, October 03, 2016

Corrective Action Required
3 Misc 1

NOTCHING/BORING OF NON-BEARING STUDS: INSTALLATION OF
STUD SHOES INCOMPLETE. **NAIL AT ALL NAIL HOLES PROVIDED.**

Corrective Action Required
5 Misc 1

NM ELECT CABLE TO EXTERIOR RECEPTACLE TO BE REPLACED
WITH MC CABLE BECAUSE IT RUNS IN ABOVE-CEILING SPACE

Comments: