

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162494, Building Permit - Commercial
Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, October 04, 2016

Partial Correction

1 Misc 1

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #2; #3; #5;

Partial Correction

2 Misc 1

GROUND RODS FOUND DRIVEN IN PLACE AND G.E.C. CAD-WELDED AT L.P. LOCATIONS: #2; #3; #5;

Partial Correction

3 Misc 1

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE LIGHTING INTERCONNECTING L.P. LOCATIONS #1 THRU #7

Comments: