

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161018, Building Permit - Commercial
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, October 04, 2016

Corrective Action Required

1	Misc 1	-THE SPLICE OF THE UFER GROUNDING ELECTRODE CONDUCTOR SHALL BE IRREVERSIBLE. SPLIT BOLT NOT ALLOWED
		**ALL OTHER UE OK

Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, October 04, 2016
---	--------------	---------	---------------------------

Corrective Action Required

1	Misc 1	UNDERSLAB PLUMBING OK ALL EXCEPT THE SPRINKLER RM & ITS CONNECTION TO BUILDING DRAIN
---	--------	---

Comments: