



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20162097
Project Title: SYLVAN LEARNING
Location:

Date: October 06, 2016
Applicant:

1184 NE DOUGLAS ST, LEES SUMMIT, NATIONAL FIRE SUPPRESSION
MO 64086 501 SUNSHINE RD
KANSAS CITY, KS 66115

Type of Work:

Occupancy Group: E

Description: CHANGE OF TENANT FOR
LEARNING CENTER

Primary: (913) 321-9208

Construction Type: Type VB (Unprotected)

Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

THE EXISTING FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH ALL REQUIRED SERVICE / MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE SYSTEM RISER.
(VERIFIED AT INSPECTION)

WATCH THE MINIMUM CLEARANCE OF 4" FROM A WALL IN THE HALLWAY. RELOCATION OF THE HEAD IN THE BACK HALLWAY MAY BE REQUIRED. (VERIFIED AT INSPECTION)

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.