



## FIRE DEPARTMENT

### PLANS REVIEW CONDITIONS

Permit No: PRCOM20161245 Date: October 10, 2016  
Project Title: HYVEE MARKET GRILL Applicant:  
Location: 310 SW WARD RD, LEES SUMMIT, MO 64081 AMERICAN FIRE SPRINKLER CORPORATION  
PO BOX 958  
MISSION, KS 66201  
Type of Work:  
Occupancy Group: M Primary: (913) 722-6900  
Description: INTERIOR ALTERATIONS TO EXISTING GROCERY STORE -  
MODIFY CAFETERIA INTO  
RESTAURANT AND BUILD  
MEDICAL CLINIC  
- VERIFY THAT ALL FEES HAVE  
BEEN PAID PRIOR TO  
CLOSING  
Construction Type: Type IIIB (Unprotected)  
Map Page:

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

THE EXSISTING FIRE SPRINKLER SYSTEM RISER SHALL BE CURRENT WITH THE REQUIRED ANNUAL MAINTENANACE/SERVICE WITH A CURRENT SERVICE TAG ON THE RISER.

(verified at inspection)

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**